



STATIC SCREEN

SECTION 09 84 00

SOUND-ABSORBING WALL AND CEILING UNITS

PART 1 - GENERAL

1.01 SECTION INCLUDES

- A. Acoustic Wall Panels.

1.02 RELATED SECTIONS

- A. Section 09 84 33 - Sound-Absorbing Wall Units
- B. Section 09 84 36 - Sound-Absorbing Ceiling Units

1.03 REFERENCES

- A. ASTM C423 - Standard Test Method for Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method; 2009a.
- B. ASTM E84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2016.
- C. ASTM E795 - Standard Practices for Mounting Test Specimens During Sound Absorption Tests; 2016.

1.04 SUBMITTALS

- A. General: Submit manufacturer's documentation for each type of product under provisions of Section 01 30 30 - Administrative Requirements, for submittal procedures.
- B. Product Data: Manufacturer's printed data sheets for products specified.
- C. Shop Drawings: Fabrication and installation details, panel layout.
- D. Selection Samples: Manufacturer's color charts for applicable material, indicating full range of material, colors, and patterns available.
- E. Verification Samples: Fabricated samples of each type of product specified; 6" minimum length and width, showing construction, edge details.
- F. Test Reports: Certified test data from an independent test agency verifying that panels meet specified requirements for acoustical and fire performance.
- G. Maintenance Materials: Furnish maintenance information and recommendations for Owners use.

1.05 QUALITY ASSURANCE

- A. Source Limitations: All similar products to be obtained from a single manufacturer through one source providing a comprehensive material and installation package.
- B. Installer Qualifications: Utilization of an installer with demonstrated experience and quality in projects of similar size and complexity.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Protect acoustical units from moisture during shipment, storage, and handling. Deliver in factory-wrapped bundles; do not open bundles until units are needed for installation. Ensure all supplied hardware, material, and components are maintained until product is fully installed.

- B. Store units flat, in dry, well-ventilated space; do not stand on end.
- C. Protect edges from damage.
- D. Acclimatize product for minimum 24 hours at temperature and humidity approximately that of occupancy prior to installation.

1.07 PROJECT CONDITIONS

- A. Environmental Limitations: Do not deliver or install materials until spaces are enclosed from the exterior environment, wet work in spaces is complete and dry, and HVAC system is maintaining an ambient temperature at occupancy levels during the remainder of the construction period.
- B. Field Measurements: Installer to verify field measurements and dimensions as indicated in Design Submittal.
 - 1. Coordinate location of other product and trades with product layout.
- C. Ensure that Design Submittal signoffs and other required information are supplied in time to prevent interruption of construction process. Ensure that products of this section are supplied to affected trades in time to prevent interruptions.

1.08 WARRANTY

- A. Special Warranty: Refer to manufacturer's standard warranty for specific products, terms, and limitations.

PART 2 - PRODUCTS

2.01 MANUFACTURER

- A. Acceptable Manufacturer: TURF; Located at 2000 Fox Ln. Elgin, Illinois, 60123; Phone: 844.TURF.OMG (844.887.3664); Email: hello@turf.design; Web: www.turf.design
- B. Substitutions: Not permitted.

2.02 SOUND-ABSORBING AND SOUND-DIFFUSING PANELS

- A. Basis of Design:
 - 1. Turf Design; Product: 'Static Screen' <https://turf.design/>
- B. Material Minimum Performance Attributes:
 - 1. Surface Burning Characteristics: Flame spread index of 25 or less and smoke developed index of 450 or less, when tested in accordance with ASTM E84.
 - 2. UL Tested ASTM E-84: Class A
 - 3. Noise Reduction Coefficient (NRC): ASTM C 423: NRC .75 (material only), when tested in accordance with ASTM C423 for Type ceiling mounting, per ASTM E795.
- C. Product Attributes:
 - 1. Panel Size: As indicated in Product Order Form / Submittal Drawings and per Architects approval.
 - 2. Panel Thickness: 9 mm
 - 3. Edges: Exposed felt, machined edge.
 - 4. Corners: Square, Exposed felt, machined edge.
 - 5. Material: Polyester (PET) felt, 60% pre-consumer recycled.
 - 6. Color: As selected by Architect from manufacturer's full range.
 - 7. Patterns: As selected by Architect from manufacturer's full range and outlined in Product Order Form / Submittal Drawings. All patterns are parametric and adjust to fill full panel or across multiple panels unless noted otherwise. Patterns in cutsheet are indicative of typical designs and may vary.
 - 8. Mounting Method:
 - a. Cable side mounted from manufacturer provided ceiling to floor cable attachment system. Anchor to surfaces/structure by others.
 - b. Cable top mounted from manufacturer provided top mount ceiling cable attachment system. Anchor to surfaces/structure by others.
 - c. Standoff mounted to wall with manufacturer provided standoffs. Anchor to ceiling/structure by others.

2.03 FABRICATION

- A. General: CNC fabricate panels to sizes, configurations and patterns on 9 mm PET felt..
- B. Tolerances: Fabricate to finished tolerance of plus or minus 1/16 inch for thickness, overall length and width, and square-ness from corner to corner.

2.04 ACCESSORIES

- A. Ceiling-Suspended Accessories: Manufacturer's standard accessories at locations indicated on each acoustical unit, sized appropriately for weight of acoustical unit.

PART 3 - EXECUTION

3.01 EXAMINATION

- A. Examine substrates for conditions detrimental to installation of acoustical units. Proceed with installation only after unsatisfactory conditions have been corrected.

3.02 INSTALLATION

- A. Install acoustical units in locations indicated, following manufacturer's installation instructions and in accordance with local jurisdiction authorities.
 - 1. **For side mount single system:** Provide ceiling and floor mounting points for manufacturer provided connections at indicated spacings. Anchors and blocking at ceiling, floor, or other structure by others.
 - 2. **For side mount multiple panel system:** Provide ceiling and floor mounting points for manufacturer provided connections at indicated spacings. Single sided cable system and hardware at ends of panel system with double sided side mount hardware between panels. Anchors and blocking at ceiling, floor, or other structure by others.
 - 3. **For top mount system:** Provide ceiling mounting points for manufacturer provided connections from ceiling at locations indicated. Anchors and blocking at ceiling or other structure by others.
 - 4. **For standoff mounting:** Provide wall mounting points for manufacturer provided connections on wall at locations indicated. Anchors and blocking at wall by others.
- B. Align panels accurately, with edges plumb and edges level.
- C. Install acoustical units to construction tolerances of plus or minus 1/16 inch for the following:
 - 1. Plumb and level.
 - 2. Flatness.
 - 3. Width of joints.

3.03 CLEANING

- A. Clean felt facing upon completion of installation from dust and other foreign materials, following manufacturer's instructions.
- B. Vacuum occasionally to remove any particulate matter and air-borne debris or dust. Compressed air can be used to dust the material in difficult to reach areas or for large assemblies.

3.04 PROTECTION

- A. Provide protection of installed acoustical panels until completion of the work.
- B. Replace panels that cannot be cleaned and repaired to satisfaction of the Architect.

END OF SECTION